

**RAKIRO BIOTECH SYSTEMS PVT LTD**

R-466, TTC Industrial Area, MIDC
Rabale, Navi Mumbai - 400701
Tel No. +91-022-47804040
Email :- sales@rakiro.net

Doc No : TDSAGN6300
Date : 01-04-2024
Type : UDAAQ
Product Code : AGN6300

PRODUCT DATA SHEET> **INFORMATION**

Product Code: AGN6300

Product Name: Wood Fuel Additive

Application: Fireside Treatment

> **DESCRIPTION**

AGNISOL 6300 Biomas Fuel Additive is a free flowing powder, designed specially for Biomass Briquette / Biomass Pallets when used as boiler fuel in Industrty. Our additive acts as a combustion catalyst and thereby loss due to unburnt fuel gets minimized, resulting in improved combustion efficiency. Hard clinker is softened and the tendency of hard clinker formation is reduced, thereby helping in reducing furnace maintenance, while providing easy cleaning and also increases the boiler availability for long term operation. This results in reducing the smoke combustion at lower excess air levels and improved fuel economy.

> **SALIENT FEATURES**

Reduces smoking

Decrease unburned carbon

Improves fuel economy

Improves combustion

Reduces soot

Prevents Corrosion

>

> **ANALYTICAL DATA**

Appearance : BROWN TO GREEN COLOUR POWDER

Density : 1.05 - 1.25

> **HANDLING INSTRUCTIONS**

The use of protective Clothing, facemask, safety goggles, shoes and gloves are mandatory. Keep the container away from direct heat & sunlight. Keep the container closed when not in use. The product should not be swallowed and prolonged contact with the skin should be avoided. Should it come in contact with the eyes, flush with clean, cold water and get medical attention.

> **RECOMMENDED DOSAGE**

Start with an initial dosage of 1 kg of fuel additive for 1 tonne of fuel. After a week dosage should be adjusted according to the performance of the additive. If smoke persists, increase by 0.5 kg per tonne of coal for another week. Once smoking reduces, decrease the dose to 0.5 kg per tonne of coal. To get the best performance of the additive, a regular dosage of the additive alongwith addition of coal is to be maintained.