

**RAKIRO BIOTECH SYSTEMS PVT LTD**

R-466, TTC Industrial Area, MIDC  
Rabale, Navi Mumbai - 400701  
Tel No. +91-022-47804040  
Email :- sales@rakiro.net

**Doc No :** TDSWTB1200  
**Date :** 01-04-2024  
**Type :** UDAAQ  
**Product Code :** WTB1200

**PRODUCT DATA SHEET****1 INFORMATION**

Product Code: WTB1200

Product Name: Bronopol Based Biocide

Application: Cooling System Treatment

**2 DESCRIPTION**

WTB1200 based on Bronopol(2 Bromo-2 Nitropropane -1, 3-Diol ), is a broad spectrum bactericide, effective against both gram positive and gram negative bacteria. It is also a good preservative. Primary action of WTB1200 is the Oxidation of Thiol Groups to Disulphides thus disrupting the amino acid and protein structures. WTB1200 also causes membrane damage, while curbing enzymes activity and reacts with cell constituents. WTB1200 is very useful as a microbiocide in Industrial Cooling Systems. It may also be used in coating materials, Structures, Slurries, Paper mills as an effective preservative against bacteria and fungi.

**3 SALIENT FEATURES**

Broad Spectrum Biocide :

Ready to use Liquid

Effective over a wide pH range

Prevents Foul Odour

Prolongs Shelf life of Products.

Completely biodegradable

**4 ANALYTICAL DATA**

Appearance : Colourless To Pale Yellow Liquid

pH : 3.0 To 6.0

Density : 1.0 To 1.15

**5 HANDLING INSTRUCTIONS**

Keep the container away from direct heat & sunlight. Keep the container closed when not in use. The product should not be swallowed and prolonged contact with the skin should be avoided. Should it come in contact with the eyes, flush with clean, cold water and get medical attention.

**6 RECOMMENDED DOSAGE**

Cooling tower systems which are contaminated should be cleaned before the addition of biocide.

**Shock Dosage:-**

Shock dose (Initial dose) for fouled systems or at start-up or where the build up of biomass is apparent should be 100 - 200 PPM. Add this biocide at a point such as water basin, box etc in the distribution system that will lead to rapid distribution. This dose may be repeated once or twice a week as required to bring microbial growth under desired limits.

**Maintenance Dosage:-**

After the initial treatment, once the the microbial growth is under desired limits dose may be adjusted between 50 - 70 PPM based on microbial load analysis of the system and on the blow down of water from the system.