

**RAKIRO BIOTECH SYSTEMS PVT LTD**

R-466, TTC Industrial Area, MIDC
Rabale, Navi Mumbai - 400701
Tel No. +91-022-47804040
Email :- sales@rakiro.net

Doc No : TDSWTB1300
Date : 01-04-2024
Type : UDAAQ
Product Code : WTB1300

PRODUCT DATA SHEET**1 INFORMATION**

Product Code: WTB1300

Product Name: Dbnpa Based Biocide

Application: Cooling System Treatment

2 DESCRIPTION

The control of microbiological activity is an important, often safety critical activity in many commercial, manufacturing and industrial process applications. Our biocides are effective in controlling bacterial slime and fungal growth in industrial recirculating cooling water systems, air washer systems and evaporate condensers. Our DBNPA based broad spectrum microbiocide, which is highly effective against all type of Biofilm including sessile & planktonic organisms. It helps to keep the cooling water systems surface free from biofouling, and preserving it clean.

3 SALIENT FEATURES

Broad spectrum Biocide & Preservative.

Ready to use liquid.

Compatible with other Cooling System chemicals

Prevents foul odour

over wide PH range

Compatible with Chlorine resistant membrane.

Effective

4 ANALYTICAL DATA

Appearance : Colourless To Pale Yellow Colour Liquid

pH : Acidic

Density : 1.0 To 1.2

5 HANDLING INSTRUCTIONS

The use of protective Clothing, facemask, safety goggles, shoes and gloves are mandatory. Keep the container away from direct heat & sunlight. Keep the container closed when not in use. The product should not be swallowed and prolonged contact with the skin should be avoided. Should it come in contact with the eyes, flush with clean, cold water and get medical attention.

6 RECOMMENDED DOSAGE

Cooling tower systems which are contaminated should be cleaned before the addition of biocide.

Shock Dosage:-

Shock dose (Initial dose) for fouled systems or at start-up or where the build up of biomass is apparent should be 100 - 200 PPM. Add this biocide at a point such as water basin, box etc in the distribution system that will lead to rapid distribution. This dose may be repeated once or twice a week as required to bring microbial growth under desired limits.

Maintance Dosage:-

After the inital treatment, once the the microbial growth is under desired limits dose may be adjusted between 50 - 70 PPM based on microbial load analysis of the system and on the blow down of water from the system.